STATE OF NEBRASKA
DEPARTMENT OF ROADS
ADDENDUM NO. 3
PROJECT NO. IM-80-9(891)
CONTROL NO. 12729
CALL NO. 100
I-80, PLATTE RIVER REST AREA
LETTING DATE: JUNE 16, 2011

On plan sheet 6 (C0-1), the REFERENCED REMOVAL NOTES are amended to include the following:

- 29. General Contractor shall test (air or water) the installed system prior to building demolition for defective components and shall bid unit price to replace damaged sprinkler heads with associated damaged piping in the area as outlined on drawing sheet C1-2.
- Any damage caused by construction activities or as a result of construction activities beyond the area shown on sheet C1-2 shall be the responsibility of the awarded Contractor.

* * * * *

On plan sheet 12 (A0-1), Note No. 6 in the REFERENCED DEMOLITION NOTES is void.

* * * * *

On plan sheet 31, the ROOF FRAMING PLAN is amended as per "SUPPLEMENTAL DRAWING, REF: 1/S1-2" depicted on the attached sheet.

* * * * *

Plan sheet 37 (S3-3) is amended as follows:

- 1. Drawing 6 "HSS Beams At HSS Column Of Canopy" is amended as per the "SUPPLEMENTAL DRAWING, REF: 6/S3-3" as depicted on the attached sheet.
- 2. Drawing (10) "HSS Canopy Beam At Steel Lintel" is void and superseded by the "SUPPLEMENTAL DRAWING, REF: 10/S3-3" as depicted on the attached sheet.

* * * * *

Upon execution of the contract, the plans will be revised to reflect these changes.

DEPARTMENT OF ROADS

Original Signed by


Kendall Stege

for Claude Oie Construction Engineer

Issued: June 13, 2011

CO:100AD306

NOTICE: Only the contractors issued bidding proposals receive this addendum and responsibility for notifying any potential subcontractors or suppliers remains with the contractor.



Plan Sheet 37 6

SCHEMMER

NEBRASKA DEPARTMENT OF ROADS PLATTE RIVER REST AREA


JOB NO: 05450.001


SUPPLEMENTAL DRAWING

PROJECT:

DATE: 6/10/11 DRAWN: KMW SCALE: 3/4"=1'-0" SHEET NO: SDS-2

SHEET TITLE: HSS BEAMS AT HSS COLUMN OF CANOPY **REF:** 6/S3-3





Plan Sheet 37 (13)